

CERTIFICATE OF QUALITY

TEST	RESULTS	TEST METHODS	
DENSITY AT 15 DEG C, KG/L	0.5079	ASTM D-1657	
95% EVAPORATION AT DEG F	-39	ASTM D-1837	
VAPOR PRESSURE AT 37.8 DEG C, PSIG	177	ASTM D-1267	
HYDROGEN SULPHIDE	NEGATIVE	ASTM D-2420	
MOISTURE TEST	PASS	ASTM D-2713	
RESIDUE ON EVAPORATION, ML	< 0.05	ASTM D-2158	
OIL STAIN OBSERVATION	PASS	ASTM D-2158	
COPPER STRIP CORROSION	1	ASTM D-1838	
SULPHUR, PPMW	< 15	ASTM D-6667	
COMPOSITION:	WT %	ASTM D-2163	
METHANE	< 0.01		
ETHANE	0.13		
PROPANE	98.61		
PROPYLENE	< 0.01		
I-BUTANE	1.19		
N-BUTANE	0.07		
PENTANES & HEAVIER	< 0.01		
TOTAL UNSATURATED HC (INCLUDING PROPYLENE)	0.01		
DIENES (INCLUDING 1,3-BUTADIENE)	< 0.01		

